

---

The following amendment to the tender documents is effective immediately. This addendum shall form part of the contract documents.

---

Item Description

**DRAWINGS:**

A4.1 Ref: Drawing E-2 – Lighting Plan – New Work:

.1 Ref: Detail 1/E-2:

.1 Type B fixture is to be dimmable to 10%, as opposed to the 1% indicated by the part number.

A4.2 Ref: Drawing E-3 – Power and Systems Plan – New Work:

.1 Ref: Detail 4/E-3:

.1 Receptacles and communication outlets shown in Medication Storage Room #32 are to be installed in surface-mounted metallic raceway.

.2 Existing power panel related to Specific Note #6 is located in the adjacent Nurse's Station: allow for an additional 20 feet to the left of indicated panel location.

**END OF SECTION**