



**Planning, Development and Building Construction Division
Transportation, Infrastructure and Energy**

Tel 902 368 5060
Fax 902 368 0590
www.gov.pe.ca/
<http://www.gov.pe.ca>

PO Box 2000
Charlottetown
Prince Edward Island
Canada C1A 7N8

Addendum

Kitchen HRU Replacement Souris Hospital 2680-18061

ADDENDUM # 01

Date : November 05, 2018

Page 1 of 1

The following amendment to the tender documents is effective immediately. This addendum shall form part of the contract documents.

Note: Please indicate this addendum number on the Contract Tender Form.

Item	Description
A - 1 - 1	New Kitchen HRU controller shall integrate the existing controls from the Gaylord controller. This shall include the interlocking operation of the existing dishwasher steam exhaust fan with the operation of the HRU, control of the grease hood washdown, grease hood emergency fire suppression, and heating coil controls. The new kitchen HRU controller shall be capable of providing a 7 day programmable schedule.
A - 1 - 2	Fresh air intake shall be modified to extend the intake away from the washroom exhaust fan a minimum of 3 m (10 ft).
A - 1 - 3	Upon review of the existing emergency panel, it was noted that there was not enough space to relocate the HRU onto the emergency panel. The new HRU shall remain on the existing panel, however the breaker size shall be modified to suit the new unit.

- End of Addendum -