



**Planning, Development and Building Construction Division  
Transportation, Infrastructure and Energy**

Tel 902 368 5060  
Fax 902 368 0590  
[www.gov.pe.ca/](http://www.gov.pe.ca/)  
<http://www.gov.pe.ca>

PO Box 2000  
Charlottetown  
Prince Edward Island  
Canada C1A 7N8

# Addendum

## **Partial Roof Replacement Belfast Consolidated School Project Number: 040-19043**

---

**ADDENDUM # 3**

**Date: August 30, 2019**

**Page 1 of 1**

---

The following amendment to the tender documents is effective immediately. This addendum shall form part of the contract documents.

**Note: Please indicate this addendum number on the Contract Tender Form.**

---

<b>Item</b>	<b>Description</b>
A 3 - 1	Reference Specification Section 7J – Modified Bitumen Roofing Membrane & Accessories: 1. Refer to Item 5 - Workmanship: Clarification – As school will be in session, <b>the asphalt mopping will not be permitted</b> . The new system shall be as follows:  Option A: New membrane vapour barrier, new polyiso insulation, mechanically fastened 12.5mm asphaltic torchable substrate, torched on base sheet, and torched on cap sheet.  Option B: New membrane vapour barrier, new EPS Insulation, two layers of mechanically fastened 6mm asphaltic torchable substrate, torched on base sheet, and torched on cap sheet.  <b>- End of Addendum -</b>