



Building and Planning Division
Transportation, Infrastructure and Energy

PO Box 2000
Charlottetown
Prince Edward Island
Canada C1A 7N8

Tel 902 368 5060
Fax1 902 368 5395
Fax2 902 569 0590
www.gov.pe.ca/

Addendum

Access Summerside Interior Renovations 2060-19020

ADDENDUM #001

Date : December 11, 2019

Page 1 of 2

The following amendment to the tender documents is effective immediately. This addendum shall form part of the contract documents.

Note: Please indicate this addendum number on the Contract Tender Form.

| <u>Item</u> | <u>Description</u> |
|--------------|--|
| A-1-1 | <p><u>Refer to Drawing A1 - Construction Notes:</u></p> <p>Replace Note 2 with: Existing cabinets and sink to be removed and relocated to the New Kitchenette room as identified on the plans. Contractor to cap off existing plumbing lines within wall cavity and install new metal wall access hatch (size as required).</p> |
| A-1-2 | <p><u>Refer to Detail 1/A1 Partial Main Floor Plan:</u></p> <p>Inspectors Office, "See Note 4" should read "See Construction Note 2".</p> |
| A-1-3 | <p><u>Refer to Detail 2/A2 Main Floor - New Floor Plan:</u></p> <p>Clarification, dashed out line with note indicates approximate location of plumbing chase above.</p> |
| A-1-4 | <p><u>Refer to Drawing A2 - Demolition Notes:</u></p> <p>Add Note 11 - Contractor to remove existing water fountains (total of 2 units) located in corridors outside of washrooms and replace with water cooler with bottle filling station. Standard of acceptance or approved equal Elkay model EZS8WSVRLK. Second Floor bottle station to be located on the opposite side of wall</p> |
| A-1-5 | <p><u>Refer to Detail 3/A3 - Second Floor New Floor Plan:</u></p> <ol style="list-style-type: none"> .1 Contractor to remove existing washroom light switches and all associated boxes and wire. All new washroom lighting to tie into existing corridor lighting circuit. .2 Only one (1) emergency light fixture to be replaced with new fixture. Other existing fixture to be removed. |

A-1-6 Refer to Specifications Section 9B Acoustic Ceiling Tile:

2.1.2 CT-2

Approved Equal - CGC Mars 86300

A-1-7 Refer to Specifications Section 10B Washroom Accessories:

4. Fixtures:

Remove Item 4.1. Reuse existing toilet tissue dispensers.

- END OF ADDENDUM -