

**RICHARDSON ASSOCIATES**  
(1993) Limited  
Engineering Consultants



Telephone 902 566 4044  
Facsimile 902 566 4989  
E-mail bsear@ral93.com

P.O. Box 1057  
565 North River Road, Suite 1  
Charlottetown, Prince Edward Island  
Canada C1A 7M4

## ELECTRICAL ADDENDUM #2

Date: May 26, 2020

Project: Southern Kings Consolidated – Gym Floor Replacement and Lighting Upgrades

Project # 530-19098

Prepared by: M. McKenna

This addendum forms part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following items and prices shall be added to the tendered price for this project.

1. Refer to Electrical Drawing 4/E1 – Luminaire Schedule.

- a. Please note that the Type A luminaire has been updated. Revised catalog number is Metalux Cat. #LHB-18-UNV-L835-CD-U c/w LHB-WG23.
- b. Please note that fixture Type A is to be complete with 0-10V dimming but will not be wired for dimming.
- c. Please note the following are approved equals to the specified luminaires.

Type	Approved Equal
A	<ul style="list-style-type: none"><li>- Lithonia Cat. #IBG-18000LM-SEF-PFL-GND-HVOLT-GZ10-35K-80CRI—WGX-DWH-IBHMP</li><li>- BJ Take Cat. #BLHA-2-18-8-35K-347/480-L67-M24-G1</li><li>- GE Lighting Cat. #ABV3-D-18-T-C8-1D-Q-V-23-A-Q-W c/w wire guard</li><li>- CFI Cat. #FBY18L-835-347-LFA-FBY-PENHGR-FBY-WG</li></ul>
Exit Sign	<ul style="list-style-type: none"><li>- Ready-Lite Cat. #RS-3-W-SP c/w 460-0079RL</li><li>- Beghelli Cat. #SL-RM-SP-L-U-OLR-90SP-WG</li><li>- Lumacell Cat. #LS3-W-S-VR</li></ul>
Emergency Lighting Unit	<ul style="list-style-type: none"><li>- Ready-Lite Cat. #LDXC12-722LD10 c/w 460-0080RL</li><li>- Beghelli Cat. #SL-RM-12-72-L-U-OLR-M-2BTMR-7WLED-WG</li><li>- Lumacell Cat. #GF12C-72-2-LD10-WRG</li></ul>