



**Planning, Development and Building Construction Division
Transportation, Infrastructure and Energy**

Tel 902 368 5060
Fax 902 368 0590
www.gov.pe.ca/
<http://www.gov.pe.ca>

PO Box 2000
Charlottetown
Prince Edward Island
Canada C1A 7N8

Addendum

Eliot River Elementary Gymnasium Lighting Upgrade Project Number: 170-17069

ADDENDUM # 2

Date : October 17, 2017

Page 1 of 1

The following amendment to the tender documents is effective immediately. This addendum shall form part of the contract documents.

Note: Please indicate this addendum number on the Contract Tender Form.

Item	Description
1. <u>Reference Drawings</u>	
.1 Drawing E1 – Partial Floor Plans and Specifications	
.1 Detail 4/E1/E1 – Luminaire Schedule	
.1 Approved Equals - Type “A”	
	1. Lithonia cat. # IBG 18000LM SEF PFL WD HVOLT OZ10 35K 90CRI WGX DWH IBGPMPHB
.2 Mounting Method - Type “A”	
	1. It is acceptable to mount the luminaire directly to the underside of the existing OWSJ using the appropriate fasteners for attaching to the steel joist. For each 4’ fixture length, a minimum of three anchoring locations is required (i.e. one anchor at each end and one anchor in the middle). For the Type “A” luminaire specified in the luminaire schedule, simply remove the “HBL-SPM” option from the part number.

- End of Addendum -