



DEPARTMENT OF FINANCE

PROCUREMENT SERVICES

95 Rochford Street, 2nd Floor South, Shaw Building, Room 27

PO Box 2000, Charlottetown, PEI, C1A 7N8

Telephone: (902) 368-4040 or Facsimile (902) 368-5171

ADDENDUM # 2
For RFSO # 4933

TO: All Bidders

FROM: Procurement Services

DATE: December 28, 2017

SUBJECT: Clarification of minimum load capacities for bays with extra beams

Please carefully read what follows:

Building A - the minimum load capacity per pallet position is 2,500 lbs. On Drawings A2 and A3 for the pallet for racking 7/A2 and 8/A3 assume 8 pallet positions per bay with a 2,500 lbs. minimum load capacity/pallet position. Some bay sections show 12 pallet positions.

Building A - on Drawing A3 for racking 9/A3 requiring 144.25" wide bays assume 9 pallet positions/bay requiring the minimum load capacity of 2,500 lbs./pallet position as the racking shows 15 pallet positions.

The department requires more beams for organization for the above sections and not to increase the minimum weight requirements per bay.

Building B - the minimum load capacity per pallet position is 3,000 lbs. for all pallet positions.

Please contact Joe Carroll at 902-388-8929 if you have any questions.

END OF ADDENDUM

Please return this sheet with your formal bid proposal.