

## 1 ADDENDUM #1

**All clauses set forth in the Bidding Documents, Contract Documents and General Requirements of the original Contract Documents shall apply to and govern this work. The addendum refers to changes and additions to the original Contract Documents and is to be read in conjunction with the same. All other parts of the original Contract Documents are to be considered as applying to the work of this Contract with the exceptions and changes as noted below.**

### 1.1 SPECIFICATIONS

- .1 Reference Section 26 32 13.01 - Power Generator Diesel:
  - .1 Reference Paragraph 2.1.2:  
Delete sentence in its entirety and replace with "Generator winding insulation to be Class H".
  - .2 Reference Paragraph 2.1.5.5: Add new paragraph 2.1.5.5.1 as follows:  
".1 Pressure and temperature readings can be displayed on the generator control panel display as an alternate to physical gauges."
  - .3 Reference Paragraph 2.7.1:  
Delete sentence in its entirety and replace with "Enclosure to be fully insulated for outdoor use and non-sound attenuated."
  - .4 Reference Paragraph 2.9: Add new paragraph .4 as follows:  
".4 Fuel tank to be complete with 19L catch box around the fill pipe and a positive shutoff device which prohibits inadvertent overfilling of tank."
  - .5 Reference Paragraph 2.11.1: Add new paragraph .5 as follows:  
".5 "Generac #SD600 Series."
  - .6 Reference Paragraph 3.2: Add new paragraph .3 as follows:  
".3 The service branch for the generator set is to be located within Atlantic Canada, have a factory certified technician on call during and outside normal business hours, and as well have the ability to have a factory approved technician onsite within 1-hour of a service call."

**END OF SECTION**