

## **ADDENDUM #1**

**All clauses set forth in the Bidding Documents, Contract Documents and General Requirements of the original Contract Documents shall apply to and govern this work. The addendum refers to changes and additions to the original Contract Documents and is to be read in conjunction with the same. All other parts of the original Contract Documents are to be considered as applying to the work of this Contract with the exceptions and changes as noted below.**

### **SPECIFICATIONS**

1. Reference Section A - Invitation to Bidders - Tender:
  - .1 Delete the wording "Thursday, September 27, 2018" and replace with "Tuesday, October 02, 2018".

### **DRAWINGS**

1. Reference Drawing M1 - Demolition Plan & Details:
  - .1 Reference Detail 1:
    - .1 Add following Note:
      - .1 The Contractor can re-use an existing concrete pad as part of the new concrete pad for the boilers. If the concrete pad is not re-used, it shall be demolished and re-finished by this Contractor.
  - .2 Reference Detail 2:
    - .1 Add following Note:
      - .1 Replace existing motorized damper and ductwork with new motorized damper and ductwork. Damper/ductwork dimensions are approximately 24 inches high x 24 inches wide. Contractor to extend ductwork from existing location down to location 24 inches above the finished floor.
2. Reference Drawing M2 - Boiler Installation, Floor Plan Details
  - .1 Reference Detail 1:
    - .1 Add following Note:
      - .1 Replace existing motorized damper and ductwork with new motorized damper and ductwork. Damper/ductwork dimensions are approximately 24 inches high x 32 inches wide. Contractor to extend ductwork from existing window location down to location 24 inches above the finished floor.
  - .2 Reference Air/Hydraulic Separator Schedule:
    - .1 Add new Note:

"Acceptable Material: Armstrong, Caleffi, Flo-Fab, Taco, Bell and Gossett & Spirotherm"
3. Reference Drawing M4 - Boiler Installation, Notes & Details:
  - .1 Reference General Notes Item 4.2.1.9:
    - .1 Add "Flo-Fab" as acceptable material.
  - .2 Reference General Notes Item 4.2.2.7:
    - .1 Add "Flo-Fab" as acceptable material.
  - .3 Reference General Notes Item 5.3.2.1:
    - .1 Add "Cleaver-Brooks, Van Packar & ICC" as acceptable material.

**END OF SECTION**