

ADDENDUM #1

All clauses set forth in the Bidding Documents, Contract Documents and General Requirements of the original Contract Documents shall apply to and govern this work. The addendum refers to changes and additions to the original Contract Documents and is to be read in conjunction with the same. All other parts of the original Contract Documents are to be considered as applying to the work of this Contract with the exceptions and changes as noted below.

SPECIFICATIONS

1. Reference Section A - Invitation to Bidders - Tender:
 - .1 Delete the wording "Thursday, September 27, 2018" and replace with "Tuesday, October 02, 2018".

DRAWINGS

1. Reference Drawing M1 - Demolition Plan & Details:
 - .1 Reference Detail 1:
 - .1 Add following Note:
 - .1 The Contractor shall allow for the demolition of the existing concrete pad under one boiler. The floor shall be re-finished to match existing.
2. Reference Drawing M2 - Boiler Installation, Floor Plan Details:
 - .1 Reference Detail 1:
 - .1 Replace existing motorized damper and ductwork with new motorized damper and ductwork. Damper/ductwork dimensions are approximately 24 inches high x 32 inches wide. Contractor to extend ductwork from existing window location down to location 24 inches above the finished floor.
 - .2 Reference Boiler Schedule:
 - .1 Add new Note:

"A two (2) boiler solution with equivalent internal/capacity redundancies will be accepted as an alternate. The clear free area within the boiler room to be maintained for purposes of installing a future biomass heating plant. Contractor to fully coordinate all variances including piping, electrical and controls between equivalent options. No extra costs will be entertained for failure to coordinate."
 - .3 Reference Air/Hydraulic Separator Schedule:
 - .1 Add new Note:

"Acceptable material: Armstrong, Caleffi, Flo-Fab, Taco, Spirotherm & Bell and Gossett."
 - .4 Reference Boiler Schedule: Add "Camus" as acceptable material.
3. Reference Drawing M3 - Boiler Installation, Notes and Details:
 - .1 Reference General Notes Item 5.3.2.1:
 - .1 Add "Cleaver-Brooks, Van Packar & ICC" as acceptable material.
 - .2 Reference General Notes Item 7.1.9:
 - .1 Add "Flo-Fab" as acceptable material.
 - .3 Reference General Notes Item 7.2.7:
 - .1 Add "Flo-Fab" as acceptable material.

END OF SECTION