



**Planning, Development and Building Construction Division
Transportation, Infrastructure and Energy**

Tel 902 368 5060
Fax 902 368 0590
www.gov.pe.ca/
http://www.gov.pe.ca

PO Box 2000
Charlottetown
Prince Edward Island
Canada C1A 7N8

Addendum

Partial Roof Replacement Belfast Consolidated School Project Number: 040-19043

ADDENDUM # 4

Date: September 03, 2019

Page 1 of 1

The following amendment to the tender documents is effective immediately. This addendum shall form part of the contract documents.

Note: Please indicate this addendum number on the Contract Tender Form.

Item	Description
A -4 – 1	Reference Specification Section 7J – Modified Bitumen Roofing Membrane & Accessories: 1. Refer to Addendum # 3 – Item .1- Option A: Clarification –12.5 mm asphaltic torchable substrate should read 6 mm.

- End of Addendum -