

## **SPECIFICATIONS**

### **1. Reference Section C - Add:**

#### 46. CRIMINAL RECORD CHECKS

The successful Contractor will be required to provide the owner with a copy of a Criminal Record Check (CRC) of all employees (including all sub-contractors) working under this contract. Any CRC's older than three months from the time of construction start date will not be accepted. All CRC's must be completed from an accredited company to be considered valid.

## **DRAWINGS**

### **1. Reference Drawing E1 – Main Floor Plan and Luminaire Schedule:**

#### .1 Plan 1/E1 – Main Floor Plan

- .1 The five (5) surface mounted lights on underside of soffit to the women's unit to be replace by type "18A" light fixtures.
- .2 Replace the type "3" light fixture with a type "18B".
- .3 Replace the type "18" outside the boiler room doors with a type "18C"

#### .2 Symbol Legend

- .1 Dimmers shall be Lutron #DVSTV-WH or equal.

#### .3 Luminaire Schedule

- .1 Type 2B and 2C light fixture housings and decorative bands to be black color.
- .2 Delete Type 3 from schedule.
- .3 Change Type 15 – Recessed 8" diameter LED pot light fixture c/w new construction/remodeler housing, wide distribution white baffle, white flange, LED light engine module, 3500K, 1500 lumens, 14.2 watts, CRI >80. Halo #HC815D010 (housing), #HM81520835 (engine), #81WDWB (reflector).
- .4 Delete Type 15A from schedule.
- .5 Add Type 18A – Ceiling mounted 6" x 10" vandal resistant exterior LED light fixture c/w polycarbonate housing, marine grade die cast aluminum base plate, a one piece injection molded UV stabilized prismatic polycarbonate lens, chemically primed and finished with electrostatically applied polyester powder coat, black finish, 4000K, 806 lumens, 5 watts. Luminaire LED #SWP610-5W-4000K-120-277-CC-CP-BLK.
- .6 Add Type 18B – Ceiling mounted 6" x 10" vandal resistant exterior LED light fixture c/w polycarbonate housing, marine grade die cast aluminum base plate, a one piece injection molded UV stabilized prismatic polycarbonate lens, chemically primed and finished with electrostatically applied polyester powder coat, black finish, 4000K, 1613 lumens, 15 watts. Luminaire LED #SWP610-15W-4000K-120-277-CC-CP-BLK.
- .7 Add Type 18C – Wall mounted 6" x 10" vandal resistant exterior LED light fixture c/w polycarbonate housing, marine grade die cast aluminum base plate, a one piece injection molded UV stabilized prismatic polycarbonate lens, chemically primed and finished with electrostatically applied polyester powder coat, a chemically etched scratch resistant

surface painted les, black finish, 4000K, 1613 lumens, 15 watts.  
Luminaire LED #YWPH610-15W-4000K-120-277-CC-CP-BLK.

.8 Approved Equals:

Type 2 Kenall #MLHA8-48-F-MW-PP-45L35K-DCC-DV  
Luminaire LED #VFP84 PRD3000LM 3500K DIM1 120-277 OP WHT

Type 2A Kenall # MLHA12-48-F-MW-PP-45L35K-DCC-DV  
Luminaire LED #VFP124 50W 3500K DIM1 120-277 OP WHT

Type 2B Luminaire LED #SPC12 46" 80W 4OF 3500K 120-277 DIM1 OP BLK

Type 2C Luminaire LED #SPC4 22" 20W 2OF 3500K 120-277 DIM1 2OP BLK

Type 6 Lightolier #S7R83510Z10U  
Juno #JSF 7IN 10LM 35K 90CRI 120 FRPC WH

Type 11 Pinnacle #LF22D-A-835LO-S-U-OL2-1-GR  
Lumenwerx #PCSQS 22 ULO FH LED 80 2000 35 120 D1 1 SUR AL

Type 13 CFI #2FXP38L835-2-DS-UNV-DIM  
Lithonia #EPANL 22 34L 80CRI 35K MIN10

Type 14 CFI #OWL440L-835-UNV-DIM  
Lithonia #BLWP4 30L ADSM GZ10 LP835

Type 15 Lightolier #7R-N/R(Housing), C6L15835MZ10U(Engine), C7RDLNMWH(Trim)  
Lithonia #LDN8RV 35/15 LR8WR MVOLT GZ10 LDN8RVGIN

Type 16 Lightolier #6RR-P6RSL-15-835-WH-Z10U-  
Juno # 6RLD G3 10LM 35K 90CRI 120 FRPC WWH c/w IC22R

Type 17 CFI# FSS4-40L-835-UNV-DIM  
Lithonia #CLX L48 4000LM SEF RDL MVOLT GZ10 35K 80CRI WH

Type 17A Philips #FSS8-80L-835-UNV-DIM  
Lithonia #CLX L96 8000LM SEF RDL MVOLT GZ10 35K 80CRI WH

Type 18 Kenall #MS11ED-PP-MB-50L35K-DV

**2. Reference Drawing E3 – Partial Main Floor Lighting Plans:**

.1 Plan 1/E3 – Partial Main Floor Lighting Plan

.1 In office across from delivery entrance (room at L corner of corridor) replace the type "17" light fixture with two (2) type "13" light fixtures.

.2 Change type "15A" to type "15".

.3 Add notes

4.) Where new recessed light fixture are installed this contractor responsible to provide and install new t-bar tees to accommodate fixtures. Owner to provide new tiles to be installed by this contractor.

-END-