



**Planning, Development and Building Construction Division  
Transportation, Infrastructure and Energy**

Tel 902 368 5060  
Fax 902 368 0590  
[www.gov.pe.ca/](http://www.gov.pe.ca/)  
<http://www.gov.pe.ca>

PO Box 2000  
Charlottetown  
Prince Edward Island  
Canada C1A 7N8

# **Addendum**

## **Partial Roof Replacement Birchwood Intermediate School 050-19074**

---

**ADDENDUM # 4**

**Date: January 14, 2020**

**Page 1 of 1**

---

The following amendment to the tender documents is effective immediately. This addendum shall form part of the contract documents.

**Note: Please indicate this addendum number on the Contract Tender Form.**

---

Item	Description
A – 4 – 1	Delete all references to EPS insulation. Due to the hot asphalt mopping application, this project is to be Polyiso insulation only.

**- End of Addendum -**