



Tel 902 368 5060  
Fax 902 368 0590  
[www.gov.pe.ca/](http://www.gov.pe.ca/)  
[http://www.gov.pe.ca](http://www.gov.pe.ca/)

**Planning, Development and Building Construction Division  
Transportation, Infrastructure and Energy**

PO Box 2000  
Charlottetown  
Prince Edward Island  
Canada C1A 7N8

# Addendum

## Partial Cooling Upgrade Provincial Artifactory 3250-20045

---

**ADDENDUM # 1**

**Date: July 17, 2020**

**Page 1 of 1**

---

The following amendment to the tender documents is effective immediately. This addendum shall form part of the contract documents.

**Note: Please indicate this addendum number on the Contract Tender Form.**

---

Item	Description
A - 1 - 1	LG - Multi Zone – Mini Split System with a minimum SEER of 18.5 is an approved equal.

**- End of Addendum -**